

HYDRAULIC SYSTEM

This Building is Protected by a
Hydraulically Designed Automatic
Sprinkler System

Location 2nd floor

No. of Sprinklers 4

Basis of Design

1 DENSITY .05 GPM/SQ.FT.
2 DESIGNED AREA OF DISCHARGE 4 hrs SQ.FT.

System Demand

1 GPM DISCHARGE 67 GPM
2 RESIDUAL PRESSURE AT THE 59.9 PSI
BASE OF THE RISER

System Installed By:



GA 770-945-2330
FL 850-482-7366
TN 423-899-7434